


Declaration of Product

We the Manufacturer

SHENZHEN GROWATT NEW ENERGY TECHNOLOGY CO., LTD

Declare all Growatt inverters listed below equipped with DC insulation resistance detection circuit, according VDE V 0126-1-1:2006-02, the insulation resistance must be $\geq 1\text{k}\Omega/\text{V}$ related to maximum inverter input voltage, therefore, when choose safety standard VDE 0126, inverter DC leakage current is lower than 1mA.

- MIC600TL-X, MIC750TL-X, MIC1000TL-X, MIC1500TL-X, MIC2000TL-X, MIC2500TL-X, MIC3000TL-X, MIC3300TL-X
- MIN2500TL-XE/XH, MIN3000TL-XE/XH, MIN3600TL-XE/XH, MIN 4200TL-XE/XH, MIN5000TL-XE/XH, MIN6000TL-XE/XH
- MOD 3000TL3-X/XH, MOD 4000TL3-X/XH, MOD 5000TL3-X/XH, MOD 6000TL3-X/XH, MOD7000TL3-X/XH, MOD 8000TL3-X/XH, MOD 9000TL3-X/XH, MOD 10KTL3-X/XH, MOD 11KTL3-X, MOD 12KTL3-X, MOD 13KTL3-X, MOD 15KTL3-X
- MID 15KTL3-X, MID 17KTL3-X/X1, MID 20KTL3-X/X1, MID 22KTL3-X/X1, MID 25KTL3-X1, MID 30KTL3-X, MID 33KTL3-X, MID 36KTL3-X, MID 40KTL3-X
- MAX 50KTL3 LV, MAX 60K TL3 LV, MAX 70KTL3 LV, MAX 80KTL3 LV
- MAX 100KTL3-X LV, MAX 110KTL3-X LV, MAX 120KTL3-X LV, MAX 125KTL3-X LV



R&D Director

Shenzhen Growatt New Energy CO., LTD

2021.12.30